



DELHI TEST HOUSE[®]

(A Unit of Delhi Test House Global LLP)

A-62/3, G.T. Karnal Road, Industrial Area, Near Metro Pillar No. 600, Azadpur, Delhi-110 033 (INDIA)
 Ph. : +91-11-47075555 (30Lines) E-mail : info@delhitesthouse.com
 Website : www.delhitesthouse.com

Issued to:
 The Principal
 Summer Fields School
 Kailash Colony, New Delhi-110048



QR-0302
 Report No : 21637241220GEN17644
 Date : 27-12-2024
 Date of Receipt : 20-12-2024
 Party Ref No : SFS/2024-25/12 & DT-20.12.2024

Sample Description:-DRINKING WATER

TEST REPORT

Sl.no	Tests	Test Values	Test Method	Requirement IS:10500-2012,AMD NO-1,2,3&4
1.CHEMICAL TESTING, (WATER)				
1	COLOUR, HAZEN UNITS	: <2	IS:3025(P-4)	5 Max. Acceptable Limit. 15 Max. Permissible Limit
2	ODOUR	: Agreeable	IS:3025(P-5)	Agreeable
3	TASTE	: Agreeable	IS:3025(P-7)	Agreeable
4	TURBIDITY, NTU	: <1	IS:3025(P-10)	1 Max Acceptable Limit. 5 Max Permissible Limit.
5	pH	: 6.92	IS:3025(P-11)	6.5-8.5 No Relaxation Permissible Limit
6	TOTAL HARDNESS as CaCO ₃ , mg/l	: 60.8	IS:3025(P-21)	200 Max Acceptable Limit 600 Max Permissible Limit
7	IRON as Fe, mg/l	: BLQ(0.01)	IS:3025(P-53)	1.0 Max. Acceptable Limit No Relaxation Permissible Limit
8	CHLORIDE as Cl, mg/l	: 40.8	IS:3025(P-32)	250 Max Acceptable Limit 1000 Max Permissible Limit
9	TOTAL DISSOLVED SOLIDS, mg/l	: 177	IS:3025(P-16)	500 Max. Acceptable Limit 2000 Max Permissible Limit
10	FLUORIDE as F, mg/l	: <0.2	APHA 24TH EDITION	1.0 Max. Acceptable Limit 1.5 Max. Permissible Limit
2.BIOLOGICAL TESTING, (WATER)				
1	Coliform Organisms/100 ml	: Not Detected	IS:15185	Shall be not detectable
2	E. coli/100 ml.	: Not Detected	IS:15185	Shall be not detectable

Remarks: The sample conforms to the IS: 10500-2012 with respect to above test only.

Note- BLQ-Below Limit of Quantification, Figure in Bracket Indicate Minimum Limit of Quantification.

Note 1.No deviation from the Standard Test Method / Specification is done unless specified or requested by the client 2. While giving the conformity statement laboratory do consider Uncertainty Measurement into account 3. General terms and conditions are given on the back side of the report
 dos/doc 20-DEC-24-27-DEC-24- ULR-TC144612400007063F . For report verification email to report_verify@delhitesthouse.com

Asen
 Reviewed By

End of Report


Asen

M.C. GOEL

Authorised Signatory - Director
 Director



स्वच्छ भारत अभियान



एक कदम स्वच्छता की ओर

**MUNICIPAL CORPORATION OF DELHI
OFFICE OF THE DEPUTY HEALTH OFFICER
PUBLIC HEALTH DEPARTMENT
GREEN PARK, AURBINDO MARG,
NEW DELHI-110016**

NO. DHO/SZ/MCD/2024/D-1428

Dated: 4/10/2024

SCHOOL HEALTH CERTIFICATE

It is certified that an inspection team headed by **Sh. Raman Yadav**, Public Health Inspector from Public Health Department, South Zone inspected the **Summer Field School**, located **Kailash Colony, New Delhi- 110048**. It was found that the School has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and the campus.

The above certificate is valid for one year from date of issue.


Deputy Health Officer
South Zone

Copy to: -

- The Principal
Summer Field School,
Kailash Colony, New Delhi- 110048
New Delhi- 110048
- Office Copy

